



SUBMERGENCE LEVELS - RAIL MOUNTED PUMPS

PUMP	LIFTOUT MODEL	A BOTTOM OF WELL TO INLET	B ABSOLUTE MINIMUM SUBMERGENCE LEVEL	C "KEEN" RECOMMENDED SUBMERGENCE LEVEL
KE102/103	KL2	3-1/2"	8-1/2"	15"
K(F/H)G2	KL1(CV)	3-1/2"	8-1/2"	15"
K(H)GS2	KL1(CV)	3-3/8"	8-1/2"	15"
KHG25	KL1(CV)	3-1/2"	9"	21"
KHHG25	KL1(CV)	3-1/2"	9"	21"
KG3,5,7,103	KL3H	4-3/4"	10-1/2"	22"
KHG3,5,7	KL3H	5-3/4"	10-1/2"	22"
KGP75-150	KL3H	4-3/4"	12"	28"
K3RN	KL3H	5-3/4"	12"	28"
K3VN	KL3H	4-1/2"	12"	27"
K3RH	KL3H	5-3/4"	11"	23"
K4RH	KL4	6-1/4"	12"	24"
K4RN (3450)	KL4	6-1/4"	12"	28"
K4RN (1150/1750)	KL4	5-1/8"	12"	28"
K4VN	KL4	5-1/8"	11"	27"
K4RP (3450)	KL4	5-1/2"	13"	28"
K4RP (1150/1750)	KL4	7-1/2"	16"	32"
K4VP	KL4	7-1/2"	15"	30"
K4RB (3450)	KL4	9-1/8"	18"	36"
K4RB (1750)	KL4	8-1/2"	18"	36"
K4VB	KL4	7-1/2"	17"	35"
K4VK	KL4	6-1/2"	19"	42"
K6VB	KL6	8-3/8"	19"	38"
K8VK	KL8	16"	28"	52"
K12VK	KL12	15-1/2"	38"	61"
K14VK	KL14	15-1/2"	38"	61"

NOTE: ALL DIMENSIONS FOR REFERENCE ONLY

REV	INITIALS	DATE
A	SE	03/16/2015

		471E STATE ROUTE 250 EAST ASHLAND, OHIO 44805		PHONE: 419-207-9400 FAX: 419-207-8031	
TITLE SUBMERGENCE LEVELS - WASTEWATER PUMPS					
SCALE NTS			DWG. # KN-903		REV. A
DWG. BY SE		DATE 9/24/2014			